

TAKOMA EC LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	TAKOMA EDUCATIONAL CAMPUS	WS- 009963	12/29/2016	1	Classroom Faucet	In classroom 148	FT-122016-009963-A	< 1	FT-122016-009963-B	< 1
2	TAKOMA EDUCATIONAL CAMPUS	WS- 009977	12/29/2016	1	Classroom Faucet	In classroom 127	FT-122016-009977-A	< 1	FT-122016-009977-B	< 1
3	TAKOMA EDUCATIONAL CAMPUS	WS- 009980	12/29/2016	2	Break Room	In staff lounge 218	FT-122016-009980-A	2.1	FT-122016-009980-B	< 1
4	TAKOMA EDUCATIONAL CAMPUS	WS- 009970	12/29/2016	1	Classroom Faucet	In classroom 133	FT-122016-009970-A	< 1	FT-122016-009970-B	< 1
5	TAKOMA EDUCATIONAL CAMPUS	WS- 009975	12/29/2016	1	Classroom Faucet	In classroom 113	FT-122016-009975-A	< 1	FT-122016-009975-B	< 1
6	TAKOMA EDUCATIONAL CAMPUS	WS- 009965	12/29/2016	1	Classroom Faucet	In classroom 142	FT-122016-009965-A	< 1	FT-122016-009965-B	< 1
7	TAKOMA EDUCATIONAL CAMPUS	WS- 009988	12/29/2016	3	Break Room	In staff lounge 318	FT-122016-009988-A	< 1	FT-122016-009988-B	< 1
8	TAKOMA EDUCATIONAL CAMPUS	WS- 009971	12/29/2016	1	Classroom Faucet	In classroom 132	FT-122016-009971-A	< 1	FT-122016-009971-B	< 1
9	TAKOMA EDUCATIONAL CAMPUS	WS- 009974	12/29/2016	1	Classroom Faucet	In classroom 116	FT-122016-009974-A	< 1	FT-122016-009974-B	< 1
10	TAKOMA EDUCATIONAL CAMPUS	WS- 009976	12/29/2016	1	Classroom Faucet	In classroom 110	FT-122016-009976-A	< 1	FT-122016-009976-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

3 TAKOMA EDUCATIONAL CAMPU	S WS- 009980	1/25/2017	2	Break Room	In staff lounge 218	FT-122016-009980-A	< 1	FT-122016-009980-B	< 1